POWER GENERATION

NEF series



SPECIFICATIONS Thermodynamic Cycle Diesel 4 stroke Air Handling TAA Arrangement 6L Bore x Stroke (mm) 104 X 132 Total Displacement (I) Valves per cylinder (n°) 2 D Injection System Speed governor electronic GAC Cooling System liquid (water + 50% Paraflu11) Direction of Rotation (viewed facing flywheel) CCW Oil specifications ACEA E3-E5 Oil consumption <0.2% of fuel consumption Fuel specifications EN 590 Oil and oil filter maintenance interval for replacement [***] 600 (hours) Specific fuel consumption at: 1500 100% load I/h (g/kWh) 25.2 (212) 30.4 (213) 80% load I/h (g/kWh) 22.9 (213.5) 18.8 (210) 50% load I/h (g/kWh) 12.9 (217) 15.8 (221) Coolant capacity: engine only (I) - 24.5 Lube oil total system capacity including pipes, filters etc. (I) - 16.5 Electric system (isolated return) 24 Starting batteries: recommended capacity (Ah) 2x100 Discharge Current (EN50342) A 650 Homologation available **Emission Certification WEIGHT AND DIMENSIONS**

| PERFORMANCE | | | | |
|-----------------|----------|----------|----------|----------|
| Ratings 1 | 1500 rpm | | 1800 rpm | |
| | PRIME | STAND-BY | PRIME | STAND-BY |
| Rated Power kWm | - | 100 | - | 120 |

1236 X 780 X 793

Kg 650

PRIME POWER: The prime power is the maximum power available with varying loads for an unlimited number of hours. The average power output during a 24h period of operation must not exceed 80% of the declared prime power between the prescribed maintenance intervals and at standard environmental conditions. A 10% overload is permissible for 1 hour every 12 hours of operation.

STAND-BY POWER: The stand-by power is the maximum power available for a period of 500 hours/year with a mean load factor of 90% of the declared stand-by power. No kind of overloads is permissible for this use.

 $\textbf{CONTINUOS POWER:} \ \text{Contact the FPT sales organization}.$

Legend

Dimensions (LxWxH)
Dry Weight

Arrangement Air Handling Turbocharger Injection System Emission Standard

L (in line) TAA (Turbocharged with aftercooler) WG (Wastegate) M (Mechanical) FC (Turbocharged) VGT (Variable Geometry Turbocharger) ECR (Electronic Common Rail) NA (Naturally Aspirated) TST (Twin Stage Turbocharge) EUI (Electronic Unit Injector)

FOR INFORMATION ON THE AVAILABLE RATINGS NOT LISTED IN THIS DOCUMENT PLEASE CONTACT THE FPT INDUSTRIAL SALES NETWORK OR VISIT OUR SITE WWW.FPTINDUSTRIAL.COM



¹⁾ Net power at flywheel available after 50 hours running with a ±3% tolerance

STANDARD CONFIGURATION

FPT engine N67 WR2M equipped with:

- Double water circuit with water/water heat exchanger and air/water intercooler
- Oil drain pump Mounted air filter

- Mounted air filter
 Fuel filter
 Primary fuel filter/water separator
 Replaceable oil filter
 Electronic speed governor
 WT, OP, HWT and LOP sensors
 Front engine mounting brackets
 Flywheel housing SAE 3 and flywheel 11" ½
 Re-directable exhaust gas elbow
 Evhaust gas flavible joint
- Exhaust gas flexible joint
- Recirculed oil breather system
- Oil dipstick
- 24Vdc electrical system isolated return

- User's handbook
THE ENGINE IS SUPPLIED WITHOUT LIQUIDS

OPTIONAL EQUIPMENT

On request the engine can be supplied with:

- 230 Volt water jacket heater
- Engine wiring loom and box connections
 Instrument panel
 RINa electric system



